CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. Page 1 of 1 3225-1328:119

CATEGORY: Fire Dampers

LISTEE: Air Balance, 7301 International Drive, Holland OH 43528

Contact: Chuck Schneider (419) 865-5000 FAX (419) 865-1375

DESIGN: Models FS1H2C, FS1H3C, FS2H2C, FS2H3C, FS1V2C, FS1V3C, FS2V2C, and FS2V3C

> combination fire and smoke dampers. Single and multi blade type construction for vertical or horizontal installation. Models FS1 series are Class I leakage rated; Models FS2 series are Class II leakage rated. Combination fire and smoke dampers or intended for use in locations that are designated as both fire barriers and smoke barriers. Refer to listee's data sheet for

additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

Listed as 1½ hour fire-rated dampers for use in heating, ventilating and air conditioning duct APPROVAL:

systems passing through fire resistive walls, partitions or floors and for use in smoke control

systems. Refer to listee's Installation Instruction Manual for details.

NOTE: Refer to CSFM Listing Category 3230 for listed leakage dampers.

07-21-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JULY 21, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager